



Dominion

**DAM INSPECTION CHECKLIST
POSSUM POINT POWER STATION
POND ABC**

INSPECTION DATE: 2/18/15 1347 hrs.
WEATHER: Partly cloudy, 33°F
INSPECTED BY: Keith M. Homza

Location/ Condition	(y/n)	Change (y/n)	Comments
Low Point, A dike*			
Flow	No	No	1347 hrs. No wet spots in snow in sandbagged area.
Erosion	No	No	Sand bags and rip-rap in place under snow.
Low Point, B dike*			
Flow	No	No	1350 hrs. No wet spots in snow. Sand bags and rip -
Erosion	No	No	rap in place under snow.
Outfall water surface El. (top of stoplogs to water)			1412 hrs. 6.11". No discharge. No water seeping into concrete weir structure. [REDACTED]

* See figure below.

Additional Comments (Note any changes observed along the embankment crest or downstream slope observed from the crest.): Approx. 6" of snow covering entire area. Approx. 8" of snow on 2/16 and 2/17/15. Low tide was at 1214 hrs.

